



GOVT. OF ASSAM
OFFICE OF THE DIRECTOR,
FIRE AND EMERGENCY SERVICES, ASSAM, GUWAHATI.



NO. F&ES/FPW/179(1) - 18(2)

FORM - (G)

Dated Guwahati the 19/5/22

To,

Mr. Pradip Kr. Bhuyan,
Managing Trustee,
Faculty Higher Secondary School,
Ghurajan, North Guwahati, Assam.

RENEWAL OF NO OBJECTION CERTIFICATE IN RESPECT OF INBUILT FIRE FIGHTING/ FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN **THE FACULTY HIGHER SECONDARY SCHOOL AT GHURAJAN, NORTH GUWAHATI, KAMRUP, ASSAM.**

With reference to your completion report under No. Nil

Dated **28.04.2022** and on the basis of the Inspection Report submitted by Station Officer, Trilochan Talukdar, I hereby certify that the building as per description below at Dag No. 480,653,654,479,675,651,650,642 Patta No. 01 Mouza Sila Sinduri Ghopa, (Place North Guwahati, Ghurajan) has been inspected in respect of implementation of inbuilt Fire Fighting/ Fire Prevention/ Escape means measures and is declared fit in respect of fire safety. The Fire & Emergency Services, Assam has no objection in its occupation/ utilization for the purpose of **SCHOOL** subject to conditions mentioned below.

DETAILS OF APPROVED OCCUPATION:-

GROUND FLOOR: -

1. Floor area: - **Block A – 508.05 m² (Assam Type)**
Block B – 473.02 m², Block C – 654 m² (Assam Type)
Block D – 2085 m²

2. Purpose of utilization: -
For School purpose.

SECOND FLOOR: -

1. Floor area: - **Block B – 473.02 m²**
2. Purpose of utilization: -
For School purpose.

FIRST FLOOR: -

1. Floor area: - **Block B – 473.02 m²**
Block D – 2085 m²

2. Purpose of utilization: -
For School purpose.

Details of inbuilt Fire Fighting and Fire Prevention measures:

1. Hose reel hose system.
2. MOEFA system.
3. Terrace tank/pump.
4. Fire Extinguishers – 32 nos.

S.P. cum F&ES Adviser
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

Dated Guwahati the _____

NO. F&ES/FPW/

Copy to:-

1. The Deputy Commissioner, **Kamrup, Amingaon, Assam** for information.
2. The Superintendent of Police, **Kamrup, Assam** for information.
3. The President/Secretary, **North Guwahati Municipal Board, Assam** for information.
4. The S.O. **North Guwahati F&ES Station** for information and necessary action.

S.P. cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

CONDITIONS:-

1. The N.O.C. is valid up to: - **31.03.2023.**
2. There should not be any change of Trade for which this License has been issued.
3. There should not be any structural change in the building either horizontally or vertically.
There should not also be any change in the existing arrangements.
4. The Fire Fighting equipments should be in serviceable condition at all time.
5. Water reservoir should always be kept full up to brim.
6. The entrance and exit and the water reservoir should always be free from any obstruction/ projection.
7. **The N.O.C. is liable to be cancelled if the premises (for which the N.O.C. is granted) when inspected are not found conforming to the description and condition under which this N.O.C. is granted.**

S.P. cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.